



Robin Gilbert
Tonbridge & Malling Borough Council
Development Control
Gibson Building
Gibson Drive
Kings Hill
West Malling, Kent
ME19 4LZ

Flood and Water Management
Invicta House
Maidstone
Kent
ME14 1XX

Website: www.kent.gov.uk/flooding
Email: suds@kent.gov.uk
Tel: 03000 41 41 41
Our Ref: TMBC/2019/075151
Date: 12 September 2019

Application No: TM/19/01814/OA

Location: Development Site Land West Of Winterfield Lane East Malling West Malling Kent

Proposal: Outline Application: Erection of up to 250 new homes (40% affordable), new community building, provision of a new country park and other areas of public open spaces, areas of play, upgrade of existing footpaths, together with new vehicular accesses onto London Road and Winterfield Lane creating a new link road and associated parking and landscaping

Thank you for your consultation on the above referenced planning application.

Kent County Council as Lead Local Flood Authority have the following comments:

We have reviewed the information received and are satisfied with the proposals for dealing with surface water, namely through the use of infiltration.

On this occasion we are prepared to accept the principle that half drain times of less than 24 hours are not achievable for the larger rainfall events, this on the understanding that there will be capacity within the basins to store this additional volume. As part of the detailed design application we would expect for it to be demonstrated that this area will contain valuable landscape features and not simply be a grass slope.

Should you as LPA be minded to grant approval we would recommend that the following conditions be applied:

Condition:

Development shall not begin in any phase until a detailed sustainable surface water drainage scheme for the site has been submitted to (and approved in writing by) the local planning authority. The detailed drainage scheme shall be based upon the DRAINAGE ASSESSMENT, ref C85673-R400A and shall demonstrate that the surface water generated by this development (for all rainfall durations and intensities up to and including the climate change adjusted critical 100 year storm) can be accommodated and disposed of within the curtilage of the site without increase to flood risk on or off-site.

The drainage scheme shall also demonstrate (with reference to published guidance):

- that silt and pollutants resulting from the site use can be adequately managed to ensure there is no pollution risk to receiving waters.
- appropriate operational, maintenance and access requirements for each drainage feature or SuDS component are adequately considered, including any proposed arrangements for future adoption by any public body or statutory undertaker.

The drainage scheme shall be implemented in accordance with the approved details.

Reason:

To ensure the development is served by satisfactory arrangements for the disposal of surface water and to ensure that the development does not exacerbate the risk of on/off site flooding. These details and accompanying calculations are required prior to the commencement of the development as they form an intrinsic part of the proposal, the approval of which cannot be disaggregated from the carrying out of the rest of the development.

Condition:

No building on any phase (or within an agreed implementation schedule) of the development hereby permitted shall be occupied until a Verification Report, pertaining to the surface water drainage system and prepared by a suitably competent person, has been submitted to and approved by the Local Planning Authority. The Report shall demonstrate the suitable modelled operation of the drainage system where the system constructed is different to that approved. The Report shall contain information and evidence (including photographs) of details and locations of inlets, outlets and control structures; landscape plans; full as built drawings; information pertinent to the installation of those items identified on the critical drainage assets drawing; and, the submission of an operation and maintenance manual for the sustainable drainage scheme as constructed.

Reason:

To ensure that flood risks from development to the future users of the land and neighbouring land are minimised, together with those risks to controlled waters, property and ecological systems, and to ensure that the development as constructed is compliant with and subsequently maintained pursuant to the requirements of paragraph 165 of the National Planning Policy Framework.

This response has been provided using the best knowledge and information submitted as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Yours faithfully,

Neil Clarke

Senior Flood Risk Project Officer
Flood and Water Management



Robin Gilbert
Tonbridge & Malling Borough Council
Development Control
Gibson Building
Gibson Drive
Kings Hill
West Malling, Kent
ME19 4LZ

Flood and Water Management
Invicta House
Maidstone
Kent
ME14 1XX

Website: www.kent.gov.uk/flooding
Email: suds@kent.gov.uk
Tel: 03000 41 41 41
Our Ref: TMBC/2019/075151
Date: 19 December 2019

Application No: TM/19/01814/OA

Location: Development Site Land West Of Winterfield Lane East Malling West Malling Kent

Proposal: Outline Application: Erection of up to 250 new homes (40% affordable), new community building, provision of a new country park and other areas of public open spaces, areas of play, upgrade of existing footpaths, together with new vehicular accesses onto London Road and Winterfield Lane creating a new link road and associated parking and landscaping

Thank you for your consultation on the above referenced planning application.

We have no further comment to make on this proposal and would refer you to our previous response on 16 September 2019.

This response has been provided using the best knowledge and information submitted as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Yours faithfully,

Becca Nicholas
Technical Support Officer
Flood and Water Management