



Matthew Broome
Tonbridge & Malling Borough Council
 Development Control
 Gibson Building
 Gibson Drive
 Kings Hill
 West Malling, Kent
 ME19 4LZ

Flood and Water Management

Invicta House
 Maidstone
 Kent
 ME14 1XX

Website: www.kent.gov.uk/flooding
Email: suds@kent.gov.uk
Tel: 03000 41 41 41
Our Ref: TMBC/2019/071698
Date: 15 September 2020

Application No: TM/19/00014/OAEA

Location: Land North Of Lower Haysden Lane Tonbridge Kent

Proposal: Outline Application: The construction of up to 125 new homes, a 2 form entry primary school, the formation of new means of access onto Lower Haysden Lane, new pedestrian and cycle links (including links to the existing playing fields and Country Park to the west), the laying out of open space, new strategic landscaping, habitat creation, drainage features and associated ground works and infrastructure

Thank you for your consultation on the above referenced planning application.

Kent County Council as Lead Local Flood Authority have the following comments:

Having reviewed the latest information submitted we are satisfied that the principles proposed for dealing with surface water are acceptable and are not greatly different to those approved previously.

However since our last correspondence we now require additional conditions and the wording of some of our conditions has altered slightly and so we would now recommend the following conditions be applied should you be minded to grant permission:

Condition:

No development shall take place until the details required by Condition 1 (assumed to be reserved matters condition for layout) shall demonstrate that requirements for surface water drainage for all rainfall durations and intensities up to and including the climate change adjusted critical 100 year storm can be accommodated within the proposed development layout.

Reason:

To ensure the development is served by satisfactory arrangements for the disposal of surface water and that they are incorporated into the proposed layouts.

Condition:

Development shall not begin in any phase until a detailed sustainable surface water drainage scheme for the site has been submitted to (and approved in writing by) the local planning authority. The detailed drainage scheme shall be based upon the Flood Risk Assessment dated 14th August 2020 prepared by Brookbanks Consulting and shall

demonstrate that the surface water generated by this development (for all rainfall durations and intensities up to and including the climate change adjusted critical 100 year storm) can be accommodated and disposed of without increase to flood risk on or off-site.

The drainage scheme shall also demonstrate (with reference to published guidance):

- that silt and pollutants resulting from the site use can be adequately managed to ensure there is no pollution risk to receiving waters.
- appropriate operational, maintenance and access requirements for each drainage feature or SuDS component are adequately considered, including any proposed arrangements for future adoption by any public body or statutory undertaker.

The drainage scheme shall be implemented in accordance with the approved details.

Reason:

To ensure the development is served by satisfactory arrangements for the disposal of surface water and to ensure that the development does not exacerbate the risk of on/off site flooding. These details and accompanying calculations are required prior to the commencement of the development as they form an intrinsic part of the proposal, the approval of which cannot be disaggregated from the carrying out of the rest of the development.

Condition:

No building on any phase (or within an agreed implementation schedule) of the development hereby permitted shall be occupied until a Verification Report, pertaining to the surface water drainage system and prepared by a suitably competent person, has been submitted to and approved by the Local Planning Authority. The Report shall demonstrate the suitable modelled operation of the drainage system where the system constructed is different to that approved. The Report shall contain information and evidence (including photographs) of details and locations of inlets, outlets and control structures; landscape plans; full as built drawings; information pertinent to the installation of those items identified on the critical drainage assets drawing; and, the submission of an operation and maintenance manual for the sustainable drainage scheme as constructed.

Reason:

To ensure that flood risks from development to the future users of the land and neighbouring land are minimised, together with those risks to controlled waters, property and ecological systems, and to ensure that the development as constructed is compliant with and subsequently maintained pursuant to the requirements of paragraph 165 of the National Planning Policy Framework.

This response has been provided using the best knowledge and information submitted as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Yours faithfully,

Neil Clarke

Senior Flood Risk Project Officer
Flood and Water Management