


Fire symbols for new installations:
Existing to be re-used where installation deemed satisfactory for re-use as advised by appointed sub contractor. New installations to be installed as required and connected in to existing fire alarm system.

Fire alarm equipment shown on drawing is indicative only. It is the electrical contractors responsibility to ensure an adequate design and the electrical contractor must produce an on-site drawing showing their design to be certified, existing equipment/points to be retained and all new equipment- prior to installation.

- Alarm Call Point
- Smoke Detector
- Heat Detector
- Fire Blanket
- Alarm Sounder
- Alarm sounder with flasher unit
- Fire Action Notice
- "Fire door Keep closed" signage
- "Fire door Keep locked" signage
- "Push Bar to open" and "Fire Door Keep Clear" signage
- "Fire Door Keep Clear" signage
- 30 min fire door with smoke seals
- 60 min fire door with smoke seals
- Fire alarm control panel
- Self closing device
- Vision Panel
- Push Bar ironmongery
- 3hour self contained non-maintained luminaire
- 3 hour self contained and maintained luminaire with arrow where necessary
- 3 hour self contained and maintained external luminaire
- Carbon Dioxide extinguisher
- Water extinguisher
- Dry Powder extinguisher
- Foam extinguisher
- Wet Chemical extinguisher

Proposed Ground Floor Plan
Scale 1:100



Rev:	Date:	Init:	Note:	© Copyright
Stage: PRELIMINARY				
Client: Mark Richards				
Project address: 130 HIGH STREET TONBRIDGE KENT TN9 1DE				
Title: PROPOSED LICENSING PLAN				
Scale:	1:100	Dwg size:	A3	
Drawn by:	KM	Date:	09/23	
Drawing no:	1021-02-05	Rev:	A	
MEZELI & ALL				
2 Wings Close Broadstairs Kent CT10 1DT UK				
mezeli.co.uk karim@mezeli.co.uk				





CAD Surveys Ltd.
Suite 2 KPC House
Canterbury Road
Willesborough
Ashford
TN24 0BP

www.cadsurveys.co.uk

01233 635089

Project :

1 Castle St,
Tonbridge TN9 1BN

Drawing title :

Lower Ground Floor Plan

Scale: 1:100 @ A2	Date : 28/08/2023	Drawn by :
----------------------	----------------------	------------